


## We are proudly asbestos free.

Urban Direct Wholesale have taken action to ensure our UltraShield products are safe for Australian consumers.

**Client Reference: Urban Direct Wholesale**

|                          |       |     |  |
|--------------------------|-------|-----|--|
| Asbestos ID - materials  |       |     |  |
| Our Reference:           | UNITS | PQL | 183260-1   |
| Your Reference           | --    | --  | 'UltraShield;<br>Composite                               |
| Type of sample           | --    | --  | bulk   |
| Date analysed            | -     |     | 19/07/2016   |
| Sample Dimension         | mm    |     | 130x100x23   |
| Sample Description       | -     |     | Brown<br>Decking   |
| Asbestos ID in materials | -     |     | No asbestos<br>detected<br>Organic<br>fibres<br>detected |



**Test results from Envirolab Group - 2016**

**Following the recent controversy over imported building products used in the construction of the new Perth Children’s Hospital containing asbestos, we have taken action to ensure the same doesn’t happen to our customers, and we encourage other Perth businesses to do the same.**

We recently sent samples of our UltraShield decking to an independent Australian laboratory, Envirolab Group laboratory in Myaree, to assure that our tradesmen, customers and staff are in safe hands when working with our products.

As expected, our UltraShield composite decking came back asbestos free and packed only with natural fibres, but we felt it was better to be safe than sorry in light of recent events in the construction sector.

If you have any questions about our products, please contact us at [info@urbandirectwholesale.com.au](mailto:info@urbandirectwholesale.com.au) or on 08 9494 1051.

Please find the full and comprehensive report on the following pages.





## CERTIFICATE OF ANALYSIS 183260

**Client:**

**Cash Sale**

**Attention:** G Ranieri

**Sample log in details:**

|                                       |                                      |
|---------------------------------------|--------------------------------------|
| Your Reference:                       | <b><u>Urban Direct Wholesale</u></b> |
| No. of samples:                       | 1 x bulk                             |
| Date samples received:                | 18/07/2016                           |
| Date completed instructions received: | 18/07/2016                           |
| Location:                             |                                      |

**Analysis Details:**

Please refer to the following pages for results, methodology summary and quality control data.  
Samples were analysed as received from the client. Results relate specifically to the samples as received.

***Please refer to the last pages of this report for any comments relating to the results.***

**Report Details:**

|                             |            |
|-----------------------------|------------|
| Date results requested by:  | 20/07/16   |
| Date of Preliminary Report: | Not Issued |
| Issue Date:                 | 20/07/16   |

NATA accreditation number 2901. This document shall not be reproduced except in full.

Accredited for compliance with ISO/IEC 17025.

**Tests not covered by NATA are denoted with \*.**

**Results Approved By:**

  
\_\_\_\_\_  
Joshua Lim  
Operations Manager

MPL Reference: 183260  
Revision No: R 01



|                          |       |     |  |
|--------------------------|-------|-----|--|
| Asbestos ID - materials  |       |     |  |
| Our Reference:           | UNITS | PQL | 183260-1   |
| Your Reference           | --    | --  | 'UltraShield;<br>Composite                               |
| Type of sample           | --    | --  | bulk   |
| Date analysed            | -     |     | 19/07/2016   |
| Sample Dimension         | mm    |     | 130x100x23   |
| Sample Description       | -     |     | Brown<br>Decking   |
| Asbestos ID in materials | -     |     | No asbestos<br>detected<br>Organic<br>fibres<br>detected |

MPL Reference: 183260  
Revision No: R 01



| Method ID      | Methodology Summary   |
|----------------|---|
| <b>ASB-001</b> | Asbestos ID - Qualitative identification of asbestos in bulk samples using Polarised Light Microscopy and Dispersion Staining Techniques, including Synthetic Mineral Fibres and Organic Fibres as per Australian Standard 4964-2004. |

MPL Reference: 183260  
Revision No: R 01



**Report Comments:**

**Asbestos Signatories:**

Asbestos was analysed by Approved Identifier: Lalanee Rupasinghe  
Airborne Fibres were analysed by Approved Counter: Not applicable for this job

**Definitions:**

DOL: Sample rejected due to particulate overload RPF: Sample rejected due to Pump Failure.  
RFD: Sample rejected due to Filter Damage. RUD: Sample rejected due to uneven deposition.  
PQL: Practical Quantitation Limit

MPL Reference: 183260  
Revision No: R 01

